

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: 1510802 NAME: KERN VALLEY STATE PRISON COUNTY: KERN
 SOURCE NO: 005 NAME: AS TRT PLANT (BLEND) - EFF CLASS: OTHR STATUS: A

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	1510802 KERN VALLEY STATE PRISON	005	AS TRT PLANT (BLEND) - EFF					
IO	INORGANIC							
	01002	ARSENIC	20 / /20	11	*	50	2	5.000 UG/L
	01002	ARSENIC	2013/02/19	2.4600		10	2	5.000 UG/L
	01002	ARSENIC	2013/02/26	2.7500		10	2	5.000 UG/L
	01002	ARSENIC	2013/03/05 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/03/12 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/03/26 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/04/02 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/04/16 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/04/30 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/05/07 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/05/14 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/07/02 <	.0000		10	2	5.000 UG/L
	01002	ARSENIC	2013/07/03	7.6800	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/04	20.6000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/05	29.8000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/06	39.6000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/07	36.4000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/10	37.3000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/10	28.8000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/11	40.7000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/12	45.8000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/13	41.0000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/14	35.7000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/15	38.9000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/17	50.4000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/18	32.4000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/19	34.0000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/23	44.6000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/23	27.2000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/24	37.1000	*	10	2	5.000 UG/L
	01002	ARSENIC	2013/07/26	38.1000	*	10	2	5.000 UG/L

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2013/07/29	38.6000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/07/31	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/07/31	8.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/01	6.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/01	6.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/02	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/02	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/03	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/03	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/04	7.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/05	7.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/06	6.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/07	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/08	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/09	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/09	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/10	6.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/08/11	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/12	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/13 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/20	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/08/27 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/09/03	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/09/10	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/09/17	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/09/24	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/10/08	8.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2013/10/15	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2013/10/22	4.0000		10	2	5.000	UG/L
01002 ARSENIC	2013/10/29 <	2.0000		10	2	5.000	UG/L	
01002 ARSENIC	2013/11/05 <	2.0000		10	2	5.000	UG/L	
01002 ARSENIC	2013/11/12	2.0000		10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2014/07/08	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/07/15 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/07/22	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/07/29	7.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2014/08/05	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/08/12	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/08/19	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/08/26	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/09/01	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/09/09	5.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/09/16	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/09/23	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/09/30	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/10/07	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/10/14	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/10/21	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/10/28	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/11/04	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/11/12	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/11/18	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/11/25	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/12/02	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/12/09 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/12/16	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/12/23	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2014/12/30	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/01/05	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/01/13	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/01/20	3.0000		10	2	5.000	UG/L
01002 ARSENIC	2015/01/27	3.0000		10	2	5.000	UG/L	
01002 ARSENIC	2015/02/03	3.0000		10	2	5.000	UG/L	
01002 ARSENIC	2015/02/10	3.0000		10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2015/02/17	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/02/24	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/03/03	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/03/10 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/03/17 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/03/24	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/03/30	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/04/07	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/04/14	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/04/21	6.0000	*	10	2	5.000	UG/L
	01002 ARSENIC	2015/04/28	4.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/05/04 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/05/12 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/05/19 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/05/26 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/06/02	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/06/09	3.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/06/16 <	2.0000		10	2	5.000	UG/L
	01002 ARSENIC	2015/06/23 <	2		10	2	5.000	UG/L
	01002 ARSENIC	2015/06/30 <	2		10	2	5.000	UG/L
	01002 ARSENIC	2015/07/08	3.5		10	2	5.000	UG/L
	01002 ARSENIC	2015/07/14	00000000 00		10	2	5.000	UG/L
	01002 ARSENIC	2015/07/21	2.4		10	2	5.000	UG/L
	01002 ARSENIC	2015/07/28 <	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2015/08/11 <	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2015/08/18 <	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2015/08/25 <	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2015/09/01 <	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2015/09/08 <	2.0		10	2	5.000	UG/L
01002 ARSENIC	2015/09/24 <	2.0		10	2	5.000	UG/L	
01002 ARSENIC	2015/09/29 <	2.0		10	2	5.000	UG/L	
01002 ARSENIC	2015/10/08 <	2.0		10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2015/10/13	3.1		10	2	5.000	UG/L
	01002 ARSENIC	2015/10/20	5.2	*	10	2	5.000	UG/L
	01002 ARSENIC	2015/11/10	4.9		10	2	5.000	UG/L
	01002 ARSENIC	2015/11/17	5.9	*	10	2	5.000	UG/L
	01002 ARSENIC	2015/12/01	5.4	*	10	2	5.000	UG/L
	01002 ARSENIC	2015/12/08	4.9		10	2	5.000	UG/L
	01002 ARSENIC	2015/12/22	4.1		10	2	5.000	UG/L
	01002 ARSENIC	2015/12/29	3.6		10	2	5.000	UG/L
	01002 ARSENIC	2016/11/29	2.9		10	2	5.000	UG/L
	01002 ARSENIC	2016/12/06	2.7		10	2	5.000	UG/L
	01002 ARSENIC	2016/12/13	4.3		10	2	5.000	UG/L
	01002 ARSENIC	2016/12/22	.79		10	2	5.000	UG/L
	01002 ARSENIC	2016/12/29	00000000 00		10	2	5.000	UG/L
	01002 ARSENIC	2017/01/03	21	*	10	2	5.000	UG/L
	01002 ARSENIC	2017/01/18	5.8	*	10	2	5.000	UG/L
	01002 ARSENIC	2017/01/24	1.8		10	2	5.000	UG/L
	01002 ARSENIC	2017/01/31	1.8		10	2	5.000	UG/L
	01002 ARSENIC	2017/02/02	2.7		10	2	5.000	UG/L
	01002 ARSENIC	2017/02/07	2.0		10	2	5.000	UG/L
	01002 ARSENIC	2017/02/17	1.4		10	2	5.000	UG/L
	01002 ARSENIC	2017/02/22	4.4		10	2	5.000	UG/L
	01002 ARSENIC	2017/03/07	1.7		10	2	5.000	UG/L
	01002 ARSENIC	2017/03/14	00000000 00		10	2	5.000	UG/L
	01002 ARSENIC	2017/03/21	00000000 00		10	2	5.000	UG/L
	01002 ARSENIC	2017/03/28	00000000 00		10	2	5.000	UG/L
	01002 ARSENIC	2017/07/05	3.6		10	2	5.000	UG/L
	01002 ARSENIC	2017/07/11	2.7		10	2	5.000	UG/L
	01002 ARSENIC	2017/07/20	10	*	10	2	5.000	UG/L
	01002 ARSENIC	2017/07/25	13	*	10	2	5.000	UG/L
01002 ARSENIC	2017/08/01	2.3		10	2	5.000	UG/L	
01002 ARSENIC	2017/08/08	9.6	*	10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002	ARSENIC	2018/10/16	6.6	*	10	2	5.000 UG/L
	01002	ARSENIC	2018/10/23	5.6	*	10	2	5.000 UG/L
	01002	ARSENIC	2018/10/30	< 2.0		10	2	5.000 UG/L
	01002	ARSENIC	2018/11/06	4.8		10	2	5.000 UG/L
	01002	ARSENIC	2018/11/13	8.8	*	10	2	5.000 UG/L
	01002	ARSENIC	2018/11/20	5.3	*	10	2	5.000 UG/L
	01002	ARSENIC	2018/11/27	3.1		10	2	5.000 UG/L
	01002	ARSENIC	2018/12/04	4.6		10	2	5.000 UG/L
	01002	ARSENIC	2018/12/11	3.7		10	2	5.000 UG/L
	01002	ARSENIC	2018/12/18	11	*	10	2	5.000 UG/L
	01002	ARSENIC	2018/12/26	18	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/01/02	6.2	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/01/08	13	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/01/15	7.1	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/01/29	22	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/02/05	8.9	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/03/12	12	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/03/19	4.7		10	2	5.000 UG/L
	01002	ARSENIC	2019/03/26	5.1	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/04/02	5.5	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/04/16	5.5	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/05/21	5.4	*	10	2	5.000 UG/L
	01002	ARSENIC	2019/06/11	3.4		10	2	5.000 UG/L
	01002	ARSENIC	2019/06/18	< 2.0		10	2	5.000 UG/L
	01002	ARSENIC	2019/06/25	< 2.0		10	2	5.000 UG/L
	01002	ARSENIC	2019/07/02	5		10	2	5.000 UG/L
	01002	ARSENIC	2019/07/10	2		10	2	5.000 UG/L
	01002	ARSENIC	2019/07/17	3		10	2	5.000 UG/L
	01002	ARSENIC	2019/07/24	9	*	10	2	5.000 UG/L
01002	ARSENIC	2019/07/31	3		10	2	5.000 UG/L	
01002	ARSENIC	2019/08/07	4		10	2	5.000 UG/L	
01002	ARSENIC	2019/08/14	15	*	10	2	5.000 UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2019/08/21	15	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/08/28	14	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/09/04	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/09/11	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/09/18	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/09/25	2		10	2	5.000	UG/L
	01002 ARSENIC	2019/10/02	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/10/09	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/10/16	9	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/10/23	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/10/30	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/11/06	4		10	2	5.000	UG/L
	01002 ARSENIC	2019/11/13	4		10	2	5.000	UG/L
	01002 ARSENIC	2019/11/20	3		10	2	5.000	UG/L
	01002 ARSENIC	2019/11/25	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/12/05	9	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/12/11	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/12/18	5		10	2	5.000	UG/L
	01002 ARSENIC	2019/12/23	9	*	10	2	5.000	UG/L
	01002 ARSENIC	2019/12/30	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/01/08	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/01/15	9	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/01/22	10	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/01/29	10	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/02/05	10	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/02/12	9	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/02/19	9	*	10	2	5.000	UG/L
01002 ARSENIC	2020/02/26	8	*	10	2	5.000	UG/L	
01002 ARSENIC	2020/03/04	8	*	10	2	5.000	UG/L	
01002 ARSENIC	2020/03/11	9	*	10	2	5.000	UG/L	
01002 ARSENIC	2020/03/18	8	*	10	2	5.000	UG/L	
01002 ARSENIC	2020/03/25	8	*	10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2020/04/01	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/04/08	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/04/15	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/04/22	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/04/29	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/05/06	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/05/13	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/05/20	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/05/27	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/06/03	4		10	2	5.000	UG/L
	01002 ARSENIC	2020/06/10	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/06/17	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/06/24	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/07/01	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/07/08	4		10	2	5.000	UG/L
	01002 ARSENIC	2020/07/15	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/07/22	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/07/29	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/08/05	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/08/12	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/08/19	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/08/26	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/09/01	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/09/09	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/09/16	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/09/23	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/09/30	5		10	2	5.000	UG/L
	01002 ARSENIC	2020/10/07	4		10	2	5.000	UG/L
	01002 ARSENIC	2020/10/14	5		10	2	5.000	UG/L
01002 ARSENIC	2020/10/21	5		10	2	5.000	UG/L	
01002 ARSENIC	2020/10/28	4		10	2	5.000	UG/L	
01002 ARSENIC	2020/11/04	4		10	2	5.000	UG/L	

STATE OF CALIFORNIA
 DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CHAPTER 15 GROUPS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19010101 THRU 20991231
 REPORT OF SYSTEM: 1510802

SYSTEM NO: NAME: COUNTY:
 SOURCE NO: NAME: CLASS: STATUS:

PSCODE	GROUP/CONSTITUENT IDENTIFICATION	DATE	RESULT	*	MCL	DLR	TRIGGER	UNIT
1510802005	IO INORGANIC							
	01002 ARSENIC	2020/11/11	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/11/18	4		10	2	5.000	UG/L
	01002 ARSENIC	2020/11/24	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/12/09	4		10	2	5.000	UG/L
	01002 ARSENIC	2020/12/16	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/12/21	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2020/12/28	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/01/06	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/01/13	3		10	2	5.000	UG/L
	01002 ARSENIC	2021/01/21	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/01/27	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/02/03	4		10	2	5.000	UG/L
	01002 ARSENIC	2021/02/10	7	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/02/17	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/02/24	4		10	2	5.000	UG/L
	01002 ARSENIC	2021/03/02	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/03/09	8	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/03/16	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/03/23	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/03/30	4		10	2	5.000	UG/L
	01002 ARSENIC	2021/04/06	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/04/13	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/04/20	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/04/27	6	*	10	2	5.000	UG/L
	01002 ARSENIC	2021/05/04	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/05/11	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/05/18	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/05/25	5		10	2	5.000	UG/L
	01002 ARSENIC	2021/06/01	6	*	10	2	5.000	UG/L
01002 ARSENIC	2021/06/08	5		10	2	5.000	UG/L	
01002 ARSENIC	2021/06/15	6	*	10	2	5.000	UG/L	
01002 ARSENIC	2021/06/22	9	*	10	2	5.000	UG/L	

